

Test Certificate



Testing Date Range From: 23/06/2014 To: 23/06/2014
*Note - Items were not function tested

| | | |
|----------------------------------|---|---------------------------|
| Client: Teresa de Roberto | Site: 36 Copperfield | Location: FLAT 203 |
| Asset ID: 23443 | Description: EXTN | Make: |
| User: JAY | Test Instrument: Seaward PrimeTest 350 18B-0322 | Comments |

| Test Type | Date | Result | Unit | Status | Next Test |
|---------------------|------------|--------|------|-------------|------------|
| Visual | 23/06/2014 | | | Pass | 23/06/2015 |
| IEC Lead Continuity | 23/06/2014 | 0.238 | ohm | Pass | 23/06/2015 |
| Insulation Voltage | 23/06/2014 | 250 | V | Information | 23/06/2015 |
| Insulation | 23/06/2014 | 186 | MOhm | Pass | 23/06/2015 |
| IEC Lead Polarity | 23/06/2014 | | | Pass | 23/06/2015 |
| Overall: Pass | | | | | |

| | | |
|-----------------|---|----------|
| Asset ID: 23444 | Description: IEC LEAD | Make: |
| User: JAY | Test Instrument: Seaward PrimeTest 350 18B-0322 | Comments |

| Test Type | Date | Result | Unit | Status | Next Test |
|---------------------|------------|--------|------|-------------|------------|
| Visual | 23/06/2014 | | | Pass | 23/06/2015 |
| IEC Lead Continuity | 23/06/2014 | 0.212 | ohm | Pass | 23/06/2015 |
| Insulation Voltage | 23/06/2014 | 250 | V | Information | 23/06/2015 |
| Insulation | 23/06/2014 | 176 | MOhm | Pass | 23/06/2015 |
| IEC Lead Polarity | 23/06/2014 | | | Pass | 23/06/2015 |
| Overall: Pass | | | | | |

| | | |
|-----------------|---|-----------|
| Asset ID: 23445 | Description: AC ADAPTOR | Make: ZMX |
| User: JAY | Test Instrument: Seaward PrimeTest 350 18B-0322 | Comments |

| Test Type | Date | Result | Unit | Status | Next Test |
|--------------------|------------|--------|------|-------------|------------|
| Visual | 23/06/2014 | | | Pass | 23/06/2015 |
| Insulation Voltage | 23/06/2014 | 500 | V | Information | 23/06/2015 |
| Insulation | 23/06/2014 | > 199 | MOhm | Pass | 23/06/2015 |
| Overall: Pass | | | | | |

| | | |
|-----------------|---|-----------|
| Asset ID: 23446 | Description: AMPLIFIER | Make: PRO |
| User: JAY | Test Instrument: Seaward PrimeTest 350 18B-0322 | Comments |

| Test Type | Date | Result | Unit | Status | Next Test |
|--------------------|------------|--------|------|-------------|------------|
| Visual | 23/06/2014 | | | Pass | 23/06/2015 |
| Earth Continuity | 23/06/2014 | 0.092 | ohm | Pass | 23/06/2015 |
| Insulation Voltage | 23/06/2014 | 500 | V | Information | 23/06/2015 |
| Insulation | 23/06/2014 | > 199 | MOhm | Pass | 23/06/2015 |
| Overall: Pass | | | | | |

Total Tests: 4

Signed By:

